

STOP CORONA VIRUS-Wash Your Hand/Wear Mask/Maintain Social Distance




Delhi Jal Board

No.DJB/QCLTYR/PD/230607

DELHI JAL BOARD
(GOVT. OF N.C.T. DELHI)
QUALITY CONTROL LABORATORY,
TRANS YAMUNA REGION TAJIRPUR DELHI-110093



Licence No- CRO/QM/L-8004274 as per IS/ISO 9001:2015



NO: DJB/ACWA(TYR)/2023.....

DATE: - 14-06-2023

Analysis report of DJB supply water samples collected from (1) Inlet (2) Outlet. M/S Arwachin Bharti Bhawan Senior Secondary School Vivek Vihar, Delhi- 110095. for drinking purpose.
Challan No: - 106 dated: - 08-06-2023

Date of collection: - 12-06-2023

S. No.	PARTICULARS	BIS:10500-2012 LIMITS		UNITS	RESULT	
		Desirable	Permissible		(1)	(2)
A. Physical Examination						
1.	Colour	-	Clear	Clear
2.	Odour	-	Chlor.	Chlor.
3.	Turbidity	1.0	5.0	NTU	0.50	0.45
4.	pH Value	6.5-8.5	--	-	7.5	7.5
5.	Electrical Conductivity	--	--	µs/cm	252	253
6.	Total Dissolved Solids	500	2000	mg/l	164	164
B. Chemical Examination						
7.	P ^h Alkalinity	45	NO RELAXATION	mg/l	NIL	NIL
8.	Total Alkalinity	200	600	mg/l	64	66
9.	Total Hardness	200	600	mg/l	82	84
10.	Calcium Hardness	mg/l	62	66
11.	Magnesium Hardness	mg/l	20	18
12.	Calcium as (Ca)	75	200	mg/l	24.8	26.4
13.	Magnesium as (Mg)	30	100	mg/l	4.80	4.32
14.	Ammonical Nitrogen	0.5	NO RELAXATION	mg/l	N.D	N.D
15.	Nitrite	mg/l	N.D	N.D
16.	Nitrate	45	NO RELAXATION	mg/l	1.68	1.54
17.	Sulphate	200	400	mg/l	26.24	27.50
18.	Chloride	250	1000	mg/l	22	22
19.	Fluoride	1.0	1.5	mg/l	0.16	0.11
20.	Total Iron	1.0	NO RELAXATION	mg/l	0.10	0.08
21.	Cyanide	0.05	NO RELAXATION	mg/l	N.D.	N.D.
22.	Residual Chlorine	0.2	1.0	mg/l	0.94	0.91
C. Bacteriological Examination						
23.	Coliform count	Absent	NO RELAXATION	MPN/100ml	0	0

REMARKS:- On the basis of above tested parameters, both water samples conforms BIS: 10500-2012 and can be considered fit for drinking purpose.

14/06/2023
ACHEMIST

14/06/2023
CHEMIST

Asst. Chief Analyst
D.J.B. Govt. of N.C.T. of Delhi
Quality Control Zonal Laboratory (TYR)
Tajir Pur Dishaad Garden, Delhi-93

MUNICIPAL COPORATION OF DELHI
PUBLIC HEALTH DEPARTMENT
SHAHDARA NORTH ZONE

No. DHO/Shah (N)/2023/D--622.


Dated: 17/8/23

SCHOOL INSPECTION REPORT


In reference to your application duly submitted in the office of undersigned vide diary no. 614 dated 14.06.2023, the inspection of "ARWACHIN BHARTI BHAWAN SR. SEC. SCHOOL" at C-Block, Vivek Vihar, Delhi-110095 was carried out on dated 16.08.2023. During the inspection, it was found that the school is running under satisfactory sanitary & hygienic conditions. Provision of latrines & urinals is sufficient according to the number of students.

In view of the above findings, undersigned is hereby pleased to grant "PROVISIONAL NO OBJECTION CERTIFICATE FROM HEALTH POINT OF VIEW" to the above-said school. This certificate is valid for a period of one year from the date of issue.

Principal
ARWACHIN BHARTI BHAWAN SR. SEC. SCHOOL
C-Block, Vivek Vihar
Delhi-110095



Manager
Arwachin Bharti Bhawan Sr. Sec. Sc
C-Block, Vivek Vihar, Delhi-110095



Dy. Health Officer
Shahdara North Zone
Deputy Health Officer
Shahdara North Zone
Municipal Corporation of Delhi