

B-6

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE, NEW DELHI

No. F6/DFS/MS/School/SZ/2024/ 97

Dated: 13/02/2024

FIRE SAFETY CERTIFICATE

Certified that the building of Queen's Valley School, Located at Site-B, Sector - 08, Dwarka, New Delhi comprised of basement, Ground + 03 Upper Floor was issued FSC vide Letter No. F6/DFS/MS/School/2020/SZ/51, dated 12/02/2020. The premises was re inspected by the officer concerned of this department on 29/01/2024 in the presence of Sh. Sunil (Administrative Head) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education GNCT of Delhi circular No: 262 - 362 dated 17/01/2005 and that the premises is fit for occupancy class B "Educational building" with effect from 13/02/2024 for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 13/02/2024..... at New Delhi by.



(Atul Garg)
Director
Delhi Fire Service.


Copy to: -

1. The Principal, Queen's Valley School, Located at Site-B, Sector - 08, Dwarka, New Delhi.
2. Director of Education Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building by laws.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expired.


DR. (MRS.) NAMITA SHARMA
Principal
QUEEN'S VALLEY SCHOOL
(Recognised)
Sector-8, Dwarka New Delhi-77


(S.K. SACHDEVA)
Chairman
QUEEN'S VALLEY SCHOOL
Site-B, Sector-8, Dwarka,
New Delhi-110077