


Z-22

St-B



FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE, NEW DELHI


No. F6/DFS/MS/2024/School/215

Dated: 20/03/2024

FIRE SAFETY CERTIFICATE

Certified that the building of St. Thomas School, Located at Goyala Vihar, Near Sector-19, Dwarka, New Delhi-110074, comprised of basement, Ground + 03 Upper Floors owned/occupied by St. Thomas School was issued FSC vide Letter No. F6/DFS/MS/2021/SZ/49, dated 20-01-2021. The premises was re inspected by the officer concerned of this department on 05/03/2024 in the presence of Sh. Narësh Sharma and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class " Educational" Group B with effect from 20/03/24 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ... 20/03/2024 at New Delhi by.



(Atul Garg)  
Director  
Delhi Fire Service.

Handwritten notes and signatures in blue ink, including '34', '80%', and 'Mr. Sur D Dte (FSC)'.

Copy to: -

1. The Principal, St. Thomas School, Goyala Vihar, Near Sector-19, Dwarka, New Delhi-110074
2. Director of Education Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.

Following fire safety directives must be adhered to:-

1. A temporary structure / rooms created at terrace shall not be used for school activity.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. Basement shall be used as per building by laws.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
9. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expired.