

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATENO 620/24Date: 28/08/24

It is certified that and Inspection team headed by Nagar Swasthya Adhikari.

(Name of Officers with designation) from Ghaziabad Nagar Nigam, Health Department.

(Name of Department/Office) inspected the ST. Xavier's, High School, Village Shahpur Bamheta , NH-24, GZB.

(Name & Address of the school) on 05-08-2024 (date of Inspeclon) and found that ST. Xavier's, High School,

Ghaziabad. (Name of School) has safe drinking water facillties for the students and members of staff of the

institution and is maintaining the hygienic sanitation condition in the school building & the campus as per

norms prescribed by the Central/State U.T. Govt, with this condition that the school will follow the G.O. U.P

Plastic & Garbage use and disposal regulatory (Ammended) Rule-2018 & Management of Solid Waste Rule-

2016. The said School will maintain of safe drinking water, sanitary condition of the institute.

The above is valid for a period of 2024-2025.

Signature with Seal M. K. Singh
Name : Nagar Swasthya Adhikari
Designation : Nagar Swasthya Adhikari
Name & Address of the Office/Department: Ghaziabad
Nagar Nigam, Health Department

To,

Principal
ST. Xavier's, High School,
Village Shahpur Bamheta , NH-24, GZB.

GTL



GHAZIABAD TESTING LABORATORIES PVT. LTD.

TEST REPORT

ULR No: TC-1170724100000223F

Issued To,
M/s. St. Xaviers High School
Village- Shahpur Bamheta,
Ghaziabad (U.P.)

Report No. : 100-240718-223
Report Date : 24/07/2024
Sample Received on : 18/07/2024
Analysis Date : 18/07/2024 to 24/07/2024
Report Prepared on : 24/07/2024
Sample Collected by : Customer

Sample Description : Water for Drinking Purpose
Condition of the sample on receipt : Received in good condition

Page 1 of 1

Parameters	Unit	Test Method	Results	Requirement as per IS: 10500-2012	
				Desirable Limits	Extended Limits (in the absence of Alternate Source)
Colour	Hazen	IS: 3025 (P-4)	< 5.0	5	15
Odour	-	IS: 3025 (P-5)	Agreeable	Agreeable	Agreeable
Taste	-	IS: 3025 (P-7&8)	Agreeable	Agreeable	Agreeable
Turbidity	NTU	IS: 3025 (P-10)	<1.0	1.0	5
pH Value at 25°C	-	IS: 3025 (P-11)	7.94	6.5 – 8.5	-
Total Hardness (CaCO ₃)	(mg/l)	IS: 3025 (P-21)	106	200 (Max.)	600
Iron (Fe).	(mg/l)	IS: 3025 (P-53)	0.24	1.0 (Max.)	No Relaxation
Chloride (Cl)	(mg/l)	IS: 3025 (P-32)	41	250 (Max.)	1000
Total Dissolved Solids (TDS)	(mg/l)	IS: 3025 (P-16)	249	500 (Max.)	2000
Residual free Chlorine	(mg/l)	IS: 3025 (P-26)	Nil	0.2 (Max.)	1.0
Fluoride (as F)	(mg/l)	APHA	0.16	1.0 (Max.)	1.5
Coliform	Absent/100ml	IS: 15185-2016	Absent	Absent	Absent

Remark: Sample meets the requirement as per specified limits laid down in IS:10500-2012 Extended Limits as observed for the above test parameters only.

*****End of Report*****

Note:

- ❖ This Test report conforms to above test parameters only submitted for testing.
- ❖ Decision Rule applied- Yes/No UM ±
- ❖ The sample description is not verified in all cases and is given as described by the customer.
- ❖ Samples not drawn by us and the analysis conducted as received basis unless specified otherwise.
- ❖ Tested sample will be disposed off after 30 days from the date of issue of test report unless specified by customer.
- ❖ Complaints about this report should be communicated in writing within seven days of issue date of this report.
- ❖ This report is not to be reproduced wholly or in part and cannot be used as an evidence in the Court of law and shall not be used in the advertising media without our prior permission from the Director.
- ❖ Laboratory shall maintain the confidentiality of all information related to the samples & Test Reports



Auth. Signatory

+91-120-3116001, +91-120-3115683, +91-120-2866108

info@gtllab.org www.gtllab.org

AO-150, Amrit Steel Compound South Side, G.T. Road Indl. Area, Ghaziabad-201001 UP, India



Scanned with OKEN Scanner

Scanned with OKEN Scanner