

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI


No.F6/DFS/MS/2023/ School/147

Dated: 28/2 /2023

FIRE SAFETY CERTIFICATE

Certified that the building of ITL Public School Located at Sector – 09, Dwarka, New Delhi - 110077 comprised of Basement + G+3 UFS was issued FSC vide letter No. F6/DFS/MS/School/2020/SZ/53, dated 12/02/2020. The premises was re inspected by the officer concerned of this department on 20/02/2023 in the presence of Mr. Rajan S Rautela (Estate Manager) and found that premises have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules 2010 and that the building is fit for occupancy class B “Educational building” with effect from 28/02/2023 for a period of three years. In accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 28/02/2023 at New Delhi by.



(Sunil Chaudhary)
Chief Fire Officer
Delhi Fire Service.

Copy to:

1. The Principal, ITL Public School Located at Sector – 09, Dwarka, New Delhi - 110077.
2. Directorate of Education Old Secretariat Delhi – 110054

Following fire safety directives must be adhered to:-

- 1 All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
- 2 Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
- 3 The trained staff should be available round the clock.
- 4 Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
- 5 The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
- 6 The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. www.dfs.delhigovt.nic.in.
- 7 Basement shall be used strictly as per building bye laws.
- 8 The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.