

FORM 'H': FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[See sub-rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001


No.F.6/DFS/MS/School/2021/SZ/1031

Dated: 20/12/2021

FIRE SAFETY CERTIFICATE

Certified that the St. Martin's Diocesan School located at Church Road, Delhi Cantt, New Delhi - 110010, comprised of Ground Floor only owned / occupied by St. Martin's Memorial Educational & Welfare Society Regd., was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/2018/SZ/927 dated 04/05/2018. The premises was re-inspected by the officer concerned of Fire Service on 10/12/2021 in the presence of Smt. K. Sudha (Principal) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with the circular issued by the Director of Education dated 17/01/2005 and that the building is fit for occupancy class "Educational" (Group-B) with effect from 20/12/2021 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010.

Issued on 20/12/2021 at New Delhi by



(SUNIL CHAUDHARY)
DY. CHIEF FIRE OFFICER (S.Z.)

Copy to :-

1. The Principal, St. Martin's Diocesan School, Church Road, Delhi Cantt, New Delhi - 110010.
2. The Director of Education, South MCD, Civic Centre, Minto Road, New Delhi-110002.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape / entry / exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
3. Any loss of life or property due to non- functional fire safety measure shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of fire fighting system.
5. This Fire Safety Certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3. of UBBL-2016), if any.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.Delhigovt.nic.in.