

ACWA-TYR

Diary No. 1061 dt. 25/09/24




No.DJB/QCLTYR/PD/240905

DELHI JAL BOARD
(GOVT. OF N.C.T. DELHI)
QUALITY CONTROL LABORATORY,
TRANS YAMUNA REGION TAHIRPUR DELHI-110093



Licence No- CRO/QM/L-8004274 as per IS/ISO 9001:2015



NO: DJB/ACWA(TYR)/2024.....

DATE:- 20-09-2024

Analysis report of DJB water samples collected from (1)Inlet, (2)Outlet of M/S ARWACHIN
BHARTI BHAWAN SR. SEC. SCHOOL, VIVEK VIHAR, DELHI-110095, for drinking purpose.

Ref. No. ABBS/SSS/VV/2024-25/7703, dated : - 19.07.2024

Challan No: - 127, dated: - 22.07.2024

Date of collection : 18-09-2024

S. No.	PARTICULARS	BIS:10500-2012 LIMITS		UNITS	RESULT	
		Desirable	Permissible		(1)	(2)
A.	Physical Examination					
1.	Colour	-	Clear	Clear
2.	Odour	-	Chlor.	Chlor.
3.	Turbidity	1.0	5.0	NTU	1.31	1.46
4.	pH Value	6.5-8.5	--	-	7.5	7.5
5.	Electrical Conductivity	--	--	µs/cm	231	230
6.	Total Dissolved Solids	500	2000	mg/l	150	149
B.	Chemical Examination					
7.	P ^h Alkalinity	mg/l	NIL	NIL
8.	Total Alkalinity	200	600	mg/l	84	84
9.	Total Hardness	200	600	mg/l	98	94
10.	Calcium as (Ca)	75	200	mg/l	27.2	27.2
11.	Magnesium as (Mg)	30	100	mg/l	7.20	6.24
12.	Ammonical Nitrogen	0.5	NR	mg/l	N.D	N.D
13.	Nitrite	mg/l	N.D	N.D
14.	Nitrate	45	NR	mg/l	2.32	2.20
15.	Sulphate	200	400	mg/l	28.64	28.89
16.	Chloride	250	1000	mg/l	12	12
17.	Fluoride	1.0	1.5	mg/l	0.04	0.05
18.	Total Iron	1.0	NR	mg/l	0.08	0.09
19.	Cyanide	0.05	NR	mg/l	N.D	N.D
20.	Residual Chlorine	0.2	1.0	mg/l	0.70	0.60
C.	Bacteriological Examination					
21.	Coliform count	Absent	NR	MPN/100ml	0	0

This Report Pertains To The Particular Sample Only

REMARKS:- On the basis of above tested parameters, both water samples conform BIS: 10500-2012 and can be considered fit for drinking purpose.

(B.K Verma)
ACWA(TYR)

Asstt. Chief Water Analyst

D.J.B. Govt. of N.C.T. of Delhi

Quality Control Zonal Laboratory (Tyr)

Tahir Pur Dilshad Garden, Delhi-93

(A.G Susmitha)
BACTERIOLOGIST

(Gulesh Jainar)
CHEMIST

(Mayank Yadav)
A/CHEMIST

MUNICIPAL CORPORATION OF DELHI
OFFICE OF THE DY. HEALTH OFFICER
SHAHDARA NORTH ZONE

No. DHO/Shah(N)/2024/D- 350

Dated:- 19/9/24

SCHOOL INSPECTION REPORT

In reference to your application duly submitted in the office of undersigned vide diary no 668 dated 19.07.2024, the inspection of "ARWACHIN BHARTI BHAWAN SR. SEC. SCHOOL at C-Block Vivek Vihar Delhi-95 was carried out on dated 19.07.2024. During the inspection, it was found that the school is running under satisfactory sanitary & hygienic conditions. Provision of latrines & urinals is sufficient according to the number of students.

In view of the above findings, undersigned in hereby pleased to grant "PROVISIONAL NO OBJECTION CERTIFICATE FROM HEALTH POINT OF VIEW" to the above- said school. This certificate is valid for a period of one year from the date of issue.

19/9/24

Dy. Health Officer

Shahdara North Zone

उप-स्वास्थ्य अधिकारी
शाहदरा उत्तरी क्षेत्र
दिल्ली नगर निगम

PRINCIPAL

ARWACHIN BHARTI BHAWAN SR. SEC. SCHOOL

C-BLOCK VIVEK VIHAR DELHI-110095