

KRISHAN KUMAR

Date 25-05-2024

Structure Consultant

B-7 Extn. /64 Safdarjung Enclave

New Delhi, 110029

MCD Reg. Structure Licence No. - SE/0381

Email: kk5934860@gmail.com ; Mobile: 08168974620

STRUCTURAL STABILITY CERTIFICATE

(TO WHOM IT MAY CONCERN)

The Existing building of "Sri Venkateshwar International School" built on Sector-18, Dwarka, New Delhi - 110075. The Existing School Building Structure is used as a Centre to cater to growing need of education of children in New Delhi. Keeping in view, the structural stability in mind, the management of the school engaged us to conduct structural stability check of the Existing building.

We have conducted Non Destructive Tests and performed Structural analysis of the entire school building. Relevant clauses of National building code for Dead & Live load for the School buildings and Seismic Forces as per Zone IV (IS: 1893).

It is certified that the Existing Structure of School Building as on date is stable for which it is intended to and habitable. As the RCC members found in sound condition. No visible deflection observed in slabs. Roof found treated with waterproofing and intact.

The Certificate is issued at statutory requirement to access the structural stability of the building and shall not be treated as valid for any other purpose.

Thanks & Regards


Er. Krishan Kumar

Er. Krishan Kumar
M.Tech Structure
Se/0381
B-7 Extn 64 Safdarjung Enclave
New Delhi-110029