




No.DJB/QLTYR/PD/250201

DELHI JAL BOARD
(GOVT. OF N.C.T. DELHI)
QUALITY CONTROL LABORATORY,
TRANS YAMUNA REGION TAHIRPUR DELHI-110093



Licence No- CRO/QM/L-8004274 as per IS/ISO 9001:2015



* एक कदम स्वच्छता की ओर

NO: DJB/ACWA(TYR)/2025.....

DATE:-10-02-2025

Analysis report of DJB water Supply samples collected from (1) Inlet, (2) Outlet of M/S ARWACHIN INTERNATIONAL SCHOOL, POCKET-B, FACILITY CENTRE, DILSHAD GARDEN, DELHI-110095, for drinking purpose.

Ref. No. AIS/2025/146,

dated: - 04.02.2025

Challan No: - 257,

dated: - 04.02.2025

Date of collection : 07-02-2025

S. No.	PARTICULARS	BIS:10500-2012 LIMITS		UNITS	RESULT	
		Desirable	Permissible		(1)	(2)
A.	Physical Examination					
1.	Colour	-	Clear	Clear
2.	Odour	-	Chlor.	Chlor.
3.	Turbidity	1.0	5.0	NTU	2.93	1.83
4.	pH Value	6.5-8.5	--	-	7.5	7.5
5.	Electrical Conductivity	--	--	µs/cm	183	243
6.	Total Dissolved Solids	500	2000	mg/l	119	158
B.	Chemical Examination					
7.	P th Alkalinity	mg/l	NIL	NIL
8.	Total Alkalinity	200	600	mg/l	66	80
9.	Total Hardness	200	600	mg/l	80	92
10.	Calcium as (Ca)	75	200	mg/l	24.0	25.6
11.	Magnesium as (Mg)	30	100	mg/l	4.80	6.72
12.	Ammonical Nitrogen	0.5	NR	mg/l	N.D	N.D
13.	Nitrite	mg/l	N.D	N.D
14.	Nitrate	45	NR	mg/l	2.55	1.85
15.	Sulphate	200	400	mg/l	33.69	29.39
16.	Chloride	250	1000	mg/l	08	18
17.	Fluoride	1.0	1.5	mg/l	0.07	0.08
18.	Total Iron	1.0	NR	mg/l	0.10	0.08
19.	Cyanide	0.05	NR	mg/l	N.D	N.D
20.	Residual Chlorine	0.2	1.0	mg/l	0.55	0.50
C.	Bacteriological Examination					
21.	Coliform count	Absent	NR	MPN/100ml	0	0

REMARKS:- On the basis of above tested parameters, both water samples conform BIS: 10500-2012 and can be considered fit for drinking purpose.

A.G. Susmitha
(A.G. Susmitha)
Asst. Chief Water Analyst
DJB, Govt. of N.C.T. of Delhi
Quality Control Zonal Laboratory (TYR)
Tahir Pur Dilshad Garden, Delhi-110093

A.G. Susmitha
(A.G. Susmitha)
BACTERIOLOGIST

Gulesh Jainar
(Gulesh Jainar)
CHEMIST

Mayank Yadav
(Mayank Yadav)
A/CHEMIST

MUNICIPAL CORPORATION OF DELHI
PUBLIC HEALTH DEPARTMENT
SHAHDARA NORTH ZONE


No. DHO/Shah (N)/2024/D. 481

Dated: 25/11/24


SCHOOL INSPECTION REPORT

In reference to your application duly submitted in the office of undersigned vide diary no. 1560 dated 22.11.2024, the inspection of "ARWACHIN INTERNATIONAL SCHOOL" at Pocket B, Facility Centre, Dilshad Garden, Delhi-110095 was carried out on dated 25.11.2024. During the inspection, it was found that the school is running under satisfactory sanitary & hygienic conditions. Provision of latrines & urinals is sufficient according to the number of students.

In view of the above findings, undersigned is hereby pleased to grant "PROVISIONAL NO OBJECTION CERTIFICATE FROM HEALTH POINT OF VIEW" to the above-said school. This certificate is valid for a period of one year from the date of issue.



Principal
ARWACHIN INTERNATIONAL SCHOOL
Pocket-B, Facility Centre
Dilshad Garden, Delhi-110095



Dy. Health Officer
Shahdara North Zone

सुप. स्वास्थ्य अधिकारी
शाहदारा उत्तरी क्षेत्र
दिल्ली नगर निगम