



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F.6/DFS/MS/School/2025/SZ/ 850

Dated: 03/07/2025

**FIRE SAFETY CERTIFICATE**

Certified that the building of **Delhi Public School** located at Sector-03, Dwarka, New Delhi-110075, comprised of Ground + 03 upper floors, was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/SZ/2022/School/683 dated. 22/06/2022. The premise was re-inspected by the officer concerned of this department on 25/06/2025 in the presence of Sh. Rakesh Thakur (Estate Officer), and found that the premises have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the school premise/building is fit for occupancy class "**Educational Group B**" (School) with effect from 03/07/2025 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 03/07/2025 at New Delhi by

(ATUL GARG)  
DIRECTOR

Ph. 011-23414000

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054
2. The Principal, Delhi Public School at Sector - 03, Dwarka, New Delhi

**Conditions for the validity of Fire Safety Certificate: -**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working conditions at all time as seen during inspection.
3. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of fire-fighting system.
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, prior to its expiry.
7. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The addition/alteration in the existing building shall not be occupied by the school without getting clearance from this department else, the FSC issued shall be withdrawn/cancelled.