




No. F.6/DFS/MS/School/2025/SZ/ 953

Dated: 07 / 08 / 2025

FIRE SAFETY CERTIFICATE

Certified that the building of Venkateshwar International School located at Sector-10, Dwarka, New Delhi-110075, comprised of Basement, Ground + 04 upper floors, owned/occupied by Venkateshwar Educational Society, was issued Fire Safety Certificate vide this department letter No. F6/DFS/MS/School/2022/SWZ/643 dated 14/06/2022 (for B+G+03 UFs). The premise was re-inspected by the officer concerned of this department on 17/07/2025 in the presence of Sh. Ansul Goel (Maint. Manager) and found that the said premises up to 3rd floor have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the school building/premises is fit for occupancy class "Educational Group B" (School up to 3rd Floor only) with effect from 07 / 08 / 2025 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 07 / 08 / 2025 at New Delhi by


(Virendra Singh)
Chief Fire Officer
Delhi Fire Service
OK

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054
2. Authorized Signatory, Venkateshwar International School located at Sector-10, Dwarka, New Delhi-110075

Conditions for the validity of Fire Safety Certificate: -

1. This FSC is valid for Basement, Ground & three upper floors, 4th floor of the building shall not be occupied without intimation and clearance from this department.
2. All the means of escape/entry/exit shall be kept free from any obstruction.
3. All the fire safety arrangement provided therein shall be maintained in good working conditions at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of fire-fighting system.
5. Basement shall be used strictly in accordance with BBL/Plan.
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, prior to its expiry.
8. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in