

## Annexure C

### PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. पु.स. अ. २० / ३१-१०-२०२४ / १२८५ Dated: 28/11/24

It is certified that an inspection team headed by Yogendra Pandey

(Name of Officers with designation) from Senior F.S.O. PHED

inspected the The Espec Global School, Iqbalpur Road, Puhana  
Roorkee, Distt Haridwar U.K.

(Name & Address of the school) on 25/11/24 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. Test Report No - NC L/ED-061/05/11/24 dated 9/11/24

of Newcon Consultants & Laboratories (PHED Lab) certified that the

The Espec Global School Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the  
hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till .....

Signature with Seal:

Name

Designation

Name & Address of the Office / Department :

To The Espec Global School, Iqbalpur Road, Roorkee  
(Name & Address of the Institution) Puhana, Haridwar

25/11/24  
Yogendra Pandey  
Sr. F.S.O. Roorkee  
FDA office, Haridwar  
YOGENDRA PANDEY  
Senior Food Safety Officer  
Roorkee, Bhagwanpur  
Dist. Haridwar

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies







# Newcon Consultants & Laboratories

(GOVERNMENT APPROVED TESTING LABORATORIES)  
An ISO 9001 : 2015, ISO 14001 : 2015, ISO 45001 : 2018 Certified Laboratory

## TEST REPORT

Page No.: 1 of 2

TEST REPORT No. NCL/ED-061/05/11/24		DATE OF REPORT : 09/11/2024
Name and Address of Customer	The Espee Global School, Iqbalpur Road, Puhana, Roorkee, Haridwar, Uttarakhand	

### SAMPLING DETAILS

Sample Name	: Drinking Water	Analysis End Date	: 09/11/2024
Analysis Start Date	: 05/11/2024	Sample ID No.	: NCL/ED-061/05/11/24
Date of Sampling	: 04/11/2024	Sample Receipt Date	: 05/11/2024
Time of Sampling	: 10:40 AM	Environmental Condition	: 25±2°C
Sampling Done By	: NCL (Mr. Manish Kalra)	Sample Quantity	: 2 Ltr
Sampling Description	: Drinking Water	Packing	: PVC BOTTLE
Sampling Location	: RO WATER		
Sampling Protocol	: IS : 17614 (P-1)		
Packing Condition	: Sealed		

### TEST RESULT

S.No.	Parameters	Unit	Test Method	Result	Specification as IS : 10500, Amd. 2018	
					Desirable Limit	Permissible Limit
1	Colour	Hazen	IS:3025 (P-4)	BDL(DL-1.0)	5.0	15.0
2	Odour	-	IS:3025 (P-5)	Agreeable	Agreeable	Agreeable
3	Taste	-	IS:3025 (P-8)	Agreeable	Agreeable	Agreeable
4	Turbidity	NTU	IS:3025 (P-10)	BDL(DL-1.0)	1.0	5.0
5	pH Value	--	IS:3025 (P-11)	7.32	6.5-8.5	No Relaxation
6	Total Dissolved Solids	mg/L	IS:3025 (P-16)	174	500	2000
7	Total Hardness (as CaCO <sub>3</sub> )	mg/L	IS:3025 (P-21)	66	200	600
8	Total Alkalinity (as CaCO <sub>3</sub> )	mg/L	IS:3025 (P-23)	28	200	600
9	Chloride (as Cl)	mg/L	IS:3025 (P-32)	32	250	1000
10	Nitrate (NO <sub>3</sub> )	mg/L	IS:3025 (P-34)	BDL(DL-0.2)	45	No Relaxation
11	Sulphate (as SO <sub>4</sub> )	mg/L	IS:3025 (P-24)	BDL(DL-2.0)	200	400
12	Fluoride (as F)	mg/L	APHA 4500-F D	BDL(DL-0.1)	1.0	1.5
13	Free Residual Chlorine (as Cl <sub>2</sub> )	mg/L	IS:3025 (P-26)	BDL(DL-0.1)	0.2	1.0
14	Iron (as Fe)	mg/L	IS:3025 (P-65)	BDL(DL-0.1)	1.0	No Relaxation
15	E. Coli	cfu/100 ml	IS:15185	Absent	Shall not be	Not Specified

*Signature*

Checked by

SONU

Section Incharge



FOR NEWCON CONSULTANTS & LABORATORIES

Authorized Signatory



1. The test report refers only to the particular sample/s submitted for testing and listed parameters.
2. Endorsement of the same is neither inferred nor implied.
3. Laboratory shall maintain the confidentiality of all information related to the samples & test reports.
4. Complaints about this report should be communicated within 10 days of the issue date of this report.
5. The report is not to be produced wholly or in part without prior permission of the Managing Partner. All disputes subject to Ghaziabad Jurisdiction.

Laboratory : A-1/156, Sector-17, (Swadeshi Compound) Kavi Nagar Industrial Area, GHAZIABAD - 201 002 (U.P.)

Mobile : 9810430345, 9205501788 | Website : www.newconlab.in

E-mail : newconlab@gmail.com, newconlabfinance@gmail.com





# Newcon Consultants & Laboratories

(GOVERNMENT APPROVED TESTING LABORATORIES)  
An ISO 9001 : 2015, ISO 14001 : 2015, ISO 45001 : 2018 Certified Laboratory

Page No.: 2 of 2

TEST REPORT No. NCL/ED-061/05/11/24

DATE OF REPORT : 09/11/2024

S.No.	Parameters	Unit	Test Method	Result	Specification as IS : 10500, Amd. 2018	
					Desirable Limit	Permissible Limit
15					detectable in any 100 ml sample	
16	Total Coliform	cfu/100 ml	IS:15185	Absent	Shall not be detectable in any 100 ml sample	Not Specified

\*\*\*End of Report\*\*\*

Remarks : BDL=Below Detection Limit.

Sample confirms to IS:10500 for above test only.

See

Checked by  
**ISHA TYAGI**  
Jr. Analyst

FOR NEWCON CONSULTANTS & LABORATORIES

Authorized Signatory



1. The test report refers only to the particular sample/s submitted for testing and listed parameters.
2. Endorsement of the same is neither Inferred nor Implied.
3. Laboratory shall maintain the confidentiality of all Information related to the samples & test reports.
4. Complaints about this report should be communicated within 10 days of the Issue date of this report.
5. The report is not to be produced wholly or in part without prior permission of the Managing Partner. All disputes subject to Ghaziabad Jurisdiction.

Laboratory : A-1/156, Sector-17, (Swadeshi Compound) Kavi Nagar Industrial Area, GHAZIABAD - 201 002 (U.P.)

Mobile : 9810430345, 9205501788 | Website : www.newconlab.in

E-mail : newconlab@gmail.com, newconlabfinance@gmail.com