



DELHI JAL BOARD  
( GOVT. OF N.C.T. DELHI )  
QUALITY CONTROL LABORATORY,  
WATER TREATMENT PLANT NANGLOI, DELHI-110041



International Year  
of Cooperatives

Cooperatives Build a Better World

Water Sample Analysis report of samples collected from "Green View Public School" Dwarka Vihar, (Near  
C-16B Dwarka) Kakrola Road, Najafgarh New Delhi-110043 Vide Challan No. 209 Dt-04.11.2025.  
S1:- DJB Water Supply at above site. S2:- Drinking point at above site.

**THE TEST REPORT IS  
FOR THIS PARTICULAR  
WATER SAMPLE ONLY.**

Particulars	Units	Limit		S1	S2
		Acceptable	Permissible		
<b>PHYSICAL EXAMINATION</b>					
Date of collection	-----	--	--	18-11-2025	
Date of Analysis	-----	--	--	20-11-2025	
Colour	CU	5.0	15	Clear	
Odour	-----	No. Objectionable		No Obj.	
Turbidity	N.T.U.	1.0	5.0	3.0	1.2
PH value	-----	6.5	8.5	8.20	8.22
Electrical Conductivity	µmho/cm	--	--	346.2	365.8
Total dissolved solids	mg/l	500	2000	225	237.7
<b>CHEMICAL EXAMINATION</b>					
Phenolphthalein Alkalinity	mg/l	--	--	NIL	NIL
Total Alkalinity	mg/l	200	600	110	114
Total Hardness	mg/l	200	600	154	168
Calcium Hardness	mg/l	--	--	110	106
Magnesium Hardness	mg/l	--	--	44	62
Calcium as Ca	mg/l	75	200	40	42.4
Magnesium as Mg	mg/l	30	100	10.56	14.88
Ammonia as N	mg/l	0.5	N.R.	NIL	NIL
Nitrite as N	mg/l	---	--	NIL	NIL
Nitrate as No <sub>3</sub>	mg/l	45	N.R.	3.0	2.8
Sulphate	mg/l	200	400	26	28
Chloride	mg/l	250	1000	18	22
Fluoride	mg/l	1	1.50	0.30	0.26
Dissolve Iron	mg/l	1	N.R.	0.06	0.06
Cyanide	mg/l	0.05	N.R.	ND	ND
24. Residual Chlorine	mg/l	0.20(min)	1.0	0.60	0.30
<b>BACTERIOLOGICAL EXAMINATION</b>					
25. T. Coli-form per 100 ml at 37°C	MPN	0		0	0

REMARKS:- As per tested parameters Sample - S1 & S2 can be used for drinking purpose.


*[Signature]*  
Asstt. Chief Water Analyst  
DELHI JAL BOARD  
Govt. of N.C.T. Delhi  
Quality Control Laboratory  
Water Works Nangloi, Delhi-41

*[Signature]*  
CHEMIST

*[Signature]*  
A/BACT.



MUNICIPAL CORPORATION OF DELHI  
OFFICE OF DEPUTY HEALTH OFFICER  
NAJAFGARH ZONE



No: DHO/NGZ/MCD/2025/D-1530

Dated-18/11/2025

SCHOOL HEALTH CERTIFICATE

1. Name of the School: - GREEN VIEW PUBLIC SCHOOL
2. SCHOOL ADDRESS:- - DWARKA VIHAR(NEAR SEC-16B, DWARKA), KAKROLA ROAD, NAJAFGARH, NEW DELHI-110043.
3. NO. OF SHIFT ONE TIMING Morning. 08:00 AM TO 02:00 PM
4. NO. OF STUDENTS: BOYS- 949 GIRLS – 589 TOTAL = 1538
5. NO. OF STAFFS: MALE - 11 FEMALE – 54 TOTAL = 65

Details of Accommodations present in School

1. Floor Space in the Classroom Sufficient/insufficient **SUFFICIENT**
2. The Classrooms are Well Lighted/ill lighted **WELL LIGHTED**
3. The Classrooms are Well Ventilated/ill ventilated **WELL VENTILATED**
4. The Classrooms are kept / Not kept Neat & Clean: **NEAT AND CLEAN**
5. The Building requires/does not required Whitewash etc. **NOT REQUIRED**
6. The Drinking Water is Wholesome/Not wholesome **WHOLESOME**
7. The Latrine arrangement is Sanitary/Insanitary **SANITARY FROM HEALTH POINT OF VIEW.**

No. of toilets seats for student

1. One latrine-cum-urinal is required for 25 female student, so total is **SUFFICIENT**
2. One latrine for 40 male student is required so total is **SUFFICIENT**
3. Separate Toilet arrangement for staff present: Yes/No **YES SEPARATE EXISTS FOR STAFF.**
4. The Overall facilities: Good/ Adequate/Inadequate **GOOD FROM HEALTH POINT OF VIEW.**

*If building Department or any other govt. agency takes actions against u/a construction or any dispute, then the Health Certificate will be stand cancelled /revoked without any further intimation in this regard*

Deputy Health Officer  
Najafgarh Zone  
Municipal Corporation Of Delhi  
Health Deptt., Najafgarh Zone

*(Remarks: This Certificate is valid for one year from the date of issue and this has no bearing on any unauthorized construction)*

Note:- (Ground Plus two upper floors, 3<sup>rd</sup> floor not in use)