



No.DJB/QCLTYR/PD/260102

**DELHI JAL BOARD**  
(GOVT. OF N.C.T. DELHI)  
**QUALITY CONTROL LABORATORY,**  
**TRANS YAMUNA REGION TAHIRPUR DELHI-110093**



Licence No:- CRO/QM/L-8004274-1 as per IS/ISO 9001:2015



एक कदम स्वच्छता की ओर

NO: DJB/ACWA(TYR)/2026...852

DATE:- 12-01-2026  
16-01-2026

Analysis report of DJB water supply samples collected from (1) Inlet, (2) Outlet of ARWACHIN INTERNATIONAL SCHOOL. POCKET-B, FACILITY CENTRE, DILSHAD GARDEN, DELHI-110095 for drinking purpose.

Ref. No. AIS/2026/094,  
Challan No: - 239,

dated: - 06.01.2026  
dated: - 08.01.2026

Date of collection: 10.01.2026

S. No.	PARTICULARS	BIS:10500-2012 LIMITS		UNITS	RESULT	
		Desirable	Permissible		(1)	(2)
<b>A. Physical Examination</b>						
1.	Colour	...	...	-	CLEAR	CLEAR
2.	Odour	...	...	-	CHLOR.	CHLOR.
3.	Turbidity	1.0	5.0	NTU	1.83	2.30
4.	pH Value	6.5-8.5	---	-	7.4	7.5
5.	Electrical Conductivity	--	--	µs/cm	269	274
6.	Total Dissolved Solids	500	2000	mg/l	175	178
<b>B. Chemical Examination</b>						
7.	P <sup>h</sup> Alkalinity	...	...	mg/l	NIL	NIL
8.	Total Alkalinity	200	600	mg/l	82	80
9.	Total Hardness	200	600	mg/l	114	106
10.	Calcium as (Ca)	75	200	mg/l	30.4	32.0
11.	Magnesium as (Mg)	30	100	mg/l	9.12	6.24
12.	Ammonical Nitrogen	0.5	NR	mg/l	N.D	N.D
13.	Nitrite	...	...	mg/l	N.D	N.D
14.	Nitrate	45	NR	mg/l	1.90	1.90
15.	Sulphate	200	400	mg/l	32.26	33.19
16.	Chloride	250	1000	mg/l	10	12
17.	Fluoride	1.0	1.5	mg/l	N.D	N.D
18.	Dissolved Iron	1.0	NR	mg/l	0.08	0.09
19.	Cyanide	0.05	NR	mg/l	N.D	N.D
20.	Residual Chlorine	0.2	1.0	mg/l	0.70	0.50
<b>C. Bacteriological Examination</b>						
21.	Coliform count	Absent	NR	MPN/100ml	0	0

REMARKS:- On the basis of above tested parameters, both water samples conform to the prescribed limits and can be considered fit for drinking purpose.

(B. Sheikhs Lal)  
ACWA(TYR)

(A.G Susmitha)  
BACTERIOLOGIST

(Gulesh Jaiar)  
CHEMIST

(Mayank Yadav)  
A/CHEMIST

Asstt. Chief Water Officer  
D.J.B. Govt. of N.C.T. of Delhi  
Quality Control Zone Laboratory (TYR)  
Tahirpur, Dilshad Garden, Delhi-93

**DELHI MUNICIPAL CORPORATION OF DELHI  
OFFICE OF THE DEPUTY HEALTH OFFICER  
SHAHDARA NORTH ZONE**

No. DHO/Shah(N)/2025//D- 857


Dated: 12/01/2026

**SCHOOL INSPECTION REPORT**

In reference to your application duly submitted in the office of undersigned vide diary no. 1871 dated 06.01.2026, The inspection of "ARWACHIN INTERNATIONAL SCHOOL" at Pocket-B, Facility Centre Dilshad Garden Delhi-110095 was carried out on dated 12.01.2026. During the inspection, it was found that the school is running under satisfactory sanitary & hygienic conditions. Provision of latrines & urinals is sufficient according to the number of students.

In view of the above findings, undersigned is hereby pleased to grant "PROVISIONAL NO OBJECTION CERTIFICATE FROM HEALTH POINT OF VIEW" to the above-said school, This certificate is valid for a period of the one year from the date of issue.

**PRINCIPAL  
ARWACHIN INTERNATIONAL SCHOOL  
POCKET-B FACILITY CENTRE  
DILSHAD GARDEN DELHI-110095**

  
**Dy. Health Officer  
Shahdara North Zone  
Deputy Health Officer  
Shahdara North Zone  
Municipal Corporation of Delhi**